


CONDUIT LANDING PANEL
16.50x7.13 [419.1x181.0]




DWG. SIZE D	DWG. NO. 096-6204		
REVISIONS			
SYM.	E.C.O.	DATE	APVD.
A	RELEASED TO PRODUCTION		
B	30141	1/24/25	
UPDATE VIEWS/REAR ENTRY			

TOP REAR VIEW
UPS


VENTILATION
CLEARANCE

CIRCUIT BREAKER
ACCESS BEHIND
DOOR




72.44 [1840.0]


REAR VIEW UPS



LEFT SIDE VIEW
UPS



FRONT VIEW UPS



FRONT VIEW UPS
DOORS REMOVED

ENVIRONMENTAL
OPERATING TEMPERATURE: 0 C TO 40° C
ALTITUDE: 0-3300 FEET [1000 METERS] (WITHOUT
DERATING)
RELATIVE HUMIDITY: 0-95%, NON-CONDENSING

SERVICE/VENTILATION CLEARANCES
FROM TOP OF CABINET: 18.00" [457.2MM]
FROM FRONT OF CABINET: 36.00" [914.4MM]
FROM REAR OF CABINET: 0" [0MM]


UL LISTED TO UL 1778, FILE NO.: E191175
UL LISTED TO UL 924 AND OUST

SEE SHEETS 3 & 4 FOR BATTERY CABINET DETAILS

(OPTIONAL)
OUTPUT DISTRIBUTION
BREAKERS

UNLESS OTHERWISE SPECIFIED, TOLERANCE IS # DECIMALS HOLES ANGLES DRAFT .XX .010 1° 1-1/2° XXX .005				UNITS IN [mm]		TITLE: SPEC. CONTROL DRAWING STACO E3 UL 924 10 KVA EMERGENCY LIGHTING SYSTEM			
MATERIAL :				ALL DIMENSIONS APPLY AFTER PLATING		DRAWN BY S.FRALEY	DATE 7/22/24	FIRST USED ON	DO NOT SCALE DWG.
The information and design disclosed herein was originated by and is the property of STACO ENERGY PRODUCTS CO., which reserves all patent, proprietary, design, manufacturing, reproduction, use and sale rights thereto, and to any article disclosed therein except to the extent rights are expressly granted to others. The foregoing does not apply to vendor proprietary parts.						CHECKER B. FOX	DATE 1/24/25	WEIGHT APPROX.	CAGE CODE 83008
						ENGINEER B FOX	DATE 1/24/25	SCALE 1/8	SHEET 1 OF 4
						DWG. SIZE D	DWG. NO. 096-6204		





8 7 6 5 4 3 2 1

DRY CONTACT
COM PORT TO
RELAY INTERFACE
SNMP CARD
SLOT


PARALLELING
CONNECTIONS

INPUT SWITCH
MAINTENANCE BYPASS
BREAKER
OUTPUT BREAKER
STATIC BYPASS
BREAKER
BATTERY BREAKER

STATIC BYPASS
CONNECTIONS
INPUT POWER
CONNECTIONS

COVER PANEL THIS AREA
FOR TRANSFORMERS IF
OTHER THAN 208V
INPUT AND OUTPUT
IS REQUIRED


FRONT VIEW UPS
DOOR REMOVED



REAR VIEW UPS
REAR PANEL REMOVED

EXTERNAL
BATTERY
CONNECTIONS
OUTPUT POWER
CONNECTIONS

ALARM RELAY
CONNECTIONS
SEE DETAIL



ISO VIEW UPS

REMOVABLE PANELS
FOR CABLE INSTALLATION

ALARM RELAY CONNECTIONS

RJ45 CONNECTOR
FOR FUTURE USE

RS-232 AND RS-485
CONNECTOR (MODBUS)

J2 - NORMAL OPERATION
J3 - ON BYPASS
J4 - ON BATTERY
J5 - LOW BATTERY
J6 - OVER TEMP
J7 -ALARM PRESENT

3.54 [90.0] TYP
6.25 [158.7]
2.33 [59.1]

REAR

BOTTOM ENTRY
CONDUIT KNOCKOUTS


BOTTOM VIEW UPS


FRONT

DWG. SIZE	DWG. NO. 096-6204		
	REVISIONS		
SYM.	E.C.O.	DATE	APVD.
A		RELEASED TO PRODUCTION	
B		30141 1/24/25	
		UPDATE VIEWS/REAR ENTRY	

UNLESS OTHERWISE SPECIFIED, TOLERANCE IS ± DECIMALS .XX .010 HOLES .005 ANGLES 1° DRAFT 1-1/2°				UNITS IN [mm]		TITLE: SPEC. CONTROL DRAWING STACO E3 UL 924 10 KVA EMERGENCY LIGHTING SYSTEM			
MATERIAL :				ALL DIMENSIONS APPLY AFTER PLATING		DRAWN BY S.FRALEY	DATE 7/22/24	FIRST USED ON	DO NOT SCALE DWG.
The information and design disclosed herein was originated by and is the property of STACO ENERGY PRODUCTS CO., which reserves all patent, proprietary, design, manufacturing, reproduction, use and sale rights thereto, and to any article disclosed therein except to the extent rights are expressly granted to others. The foregoing does not apply to vendor proprietary parts.				CHECKER B. FOX		DATE 1/24/25	WEIGHT APPROX.	CAGE CODE 83008	DWG. SIZE D
				ENGINEER B FOX		DATE 1/24/25	SCALE 1/8	SHEET 2 OF 4	DWG. NO. 096-6204







DWG. NO.	096-6204		
SYMBOL	E.C.O.	DATE	APVD.
A	RELEASED TO PRODUCTION		
B	30141	1/24/25	DESC./BATTERY CAB

TABLE											
MODEL				CIRCUIT BREAKER RATING (AMPS)			FUSE RATING (AMPS)				
E3-BAT-390-60-1-CSST				60			60				
UNLESS OTHERWISE SPECIFIED, TOLERANCE IS ± DECIMALS .XX .010 HOLE .005 ANGLES 1° DRAFT 1-1/2°				TITLES: SPEC. CONTROL DRAWING STACO E3 UL 924 10 KVA EMERGENCY LIGHTING SYSTEM			 A Components Corporation of America Company 2425 Technical Drive Miamisburg, Ohio 45342 USA				
MATERIAL :				ALL DIMENSIONS APPLY AFTER PLATING							
DRAWN BY S.FRALEY				DATE 6/26/24		FIRST USED ON				DO NOT SCALE DWG.	
CHECKER B.FOX				DATE 7/1/24		WEIGHT APPROX.				CAGE CODE 83008	
ENGINEER B.FOX				DATE 7/1/24		SCALE 1/8				SHEET 4 OF 4	
The information and design disclosed herein was originated by and is the property of STACO ENERGY PRODUCTS CO., which reserves all patent, proprietary, design, manufacturing, reproduction, use and sale rights thereto, and to any article disclosed therein except to the extent rights are expressly granted to others. The foregoing does not apply to vendor proprietary parts.							DWG. SIZE D	DWG. NO. 096-6204			