


CONDUIT LANDING PANEL
16.50x7.13 [419.1x181.0]



DWG. SIZE D	DWG. NO. 096-6205		
REVISIONS			
SYM.	E.C.O.	DATE	APVD.
A	RELEASED TO PRODUCTION		
B	30141	1/24/25	
UPDATE VIEWS/REAR ENTRY			

TOP REAR VIEW
UPS

CIRCUIT BREAKER
ACCESS BEHIND
DOOR

VENTILATION
CLEARANCE

72.44 [1840.0]

40.50 [1028.8]

32.49 [825.2]

REAR VIEW UPS

LEFT SIDE VIEW
UPS

FRONT VIEW UPS

FRONT VIEW UPS
DOORS REMOVED

ENVIRONMENTAL
OPERATING TEMPERATURE: 0 C TO 40° C
ALTITUDE: 0-3300 FEET [1000 METERS] (WITHOUT
DERATING)
RELATIVE HUMIDITY: 0-95%, NON-CONDENSING


SERVICE/VENTILATION CLEARANCES
FROM TOP OF CABINET: 18.00" [457.2MM]
FROM FRONT OF CABINET: 36.00" [914.4MM]
FROM REAR OF CABINET: 0" [0MM]

UL LISTED TO UL 1778, FILE NO.: E191175
UL LISTED TO UL 924 AND OUST

SEE SHEETS 3 & 4 FOR BATTERY CABINET DETAILS

(OPTIONAL)
OUTPUT DISTRIBUTION
BREAKERS

UNLESS OTHERWISE SPECIFIED, TOLERANCE IS ±				TITLE: SPEC. CONTROL DRAWING STACO E3 UL 924 15 KVA EMERGENCY LIGHTING SYSTEM		 A Components Corporation of America Company 2425 Technic Drive Miamisburg, Ohio 45342 USA	
DECIMALS	HOLES	ANGLES	DRAFT				
.XX .010	.005	1°	1-1/2°				
MATERIAL : .XXX .005				UNITS IN [mm]			
ALL DIMENSIONS APPLY AFTER PLATING							
The information and design disclosed herein was originated by and is the property of STACO ENERGY PRODUCTS CO., which reserves all patent, proprietary, design, manufacturing, reproduction, use and sale rights thereto, and to any article disclosed therein except to the extent rights are expressly granted to others. The foregoing does not apply to vendor proprietary parts.				DRAWN BY	DATE	FIRST USED ON	DO NOT SCALE DWG.
				S.FRALEY	7/22/24		
				CHECKER	DATE	WEIGHT APPROX.	CAGE CODE
				B. FOX	1/24/25		83008
				ENGINEER	DATE	SCALE	SHEET 1 OF 4
				B FOX	1/24/25	1/8	
				DWG. NO. 096-6205			



DWG. NO.	096-6205		
DWG. SIZE	D		
REVISIONS			
SYM.	E.C.O.	DATE	APVD.
A			
RELEASED TO PRODUCTION			
B	30141	1/24/25	
UPDATE VIEWS/REAR ENTRY			

RELEASED TO PRODUCTION			
30141	1/24/25		
UPDATE	VIEWS/REAR	ENTRY	

UNLESS OTHERWISE SPECIFIED, TOLERANCE IS ±				UNITS		TITLE: SPEC. CONTROL DRAWING STACO E3 UL 924 15 KVA EMERGENCY LIGHTING SYSTEM						STACO ENERGY PRODUCTS CO. A Components Corporation of America Company 2425 Technical Drive Miamisburg, Ohio 45342 USA			
DECIMALS	HOLES	ANGLES	DRAFT	IN	MM										
.XX .010	.005	1°	1-1/2°												
MATERIAL :						ALL DIMENSIONS APPLY AFTER PLATING									
The information and design disclosed herein was originated by and is the property of STACO ENERGY PRODUCTS CO., which reserves all patent, proprietary, design, manufacturing, reproduction, use and sale rights thereto, and to any article disclosed therein except to the extent rights are expressly granted to others. The foregoing does not apply to vendor proprietary parts.						DRAWN BY	DATE	FIRST USED ON	DO NOT SCALE DWG.	DWG. SIZE	DWG. NO.				
						S.FRALEY	6/26/24								
						CHECKER	DATE	WEIGHT APPROX.	CAGE CODE						
						B. FOX	7/22/24		83008						
						ENGINEER	DATE	SCALE	SHEET 3 OF 4						
						B FOX	7/22/24	1/8			D	096-6205			

