




DWG. SIZE D	DWG. NO. 096-6294		
REVISIONS			
SYM.	E.C.O.	DATE	APVD.
A		8/23/24	
PRELIMINARY RELEASE			
B	30141	1/26/25	
UPDATE VIEWS/REAR ENTRY			

SERVICE/VENTILATION CLEARANCES:

- FROM TOP OF CABINET: 18.00 [457.2]
FROM FRONT OF CABINET: 36.00 [914.4]
REAR: 0" [0] PLUS ANY
CLEARANCE REQUIRED FOR POWER CABLE BEND
RADIUS AND ANY FUTURE SERVICE TO CABLE
CONNECTIONS.

NOTES:

- ALL DIMENSIONS ARE IN INCHES [MM].
- KEEP CABINET WITHIN 15 DEGREES OF VERTICAL.
- UNIT BOTTOM IS STRUCTURALLY ADEQUATE FOR FORKLIFT HANDLING.
- OVERALL WIDTH DIMENSION INCLUDES HARDWARE FOR PANEL MOUNTING.

UNLESS OTHERWISE SPECIFIED, TOLERANCE IS ± DECIMALS HOLES ANGLES DRAFT .XX .010 .005 1° 1-1/2°				UNITS IN [mm]		TITLE: LINE UP DETAIL 5.0KVA UPS				 A Components Corporation of America Company 2425 Technical Drive Miamisburg, Ohio 45342 USA									
MATERIAL :				ALL DIMENSIONS APPLY AFTER PLATING		DRAWN BY R. GILBERT		DATE 8/23/24						FIRST USED ON		DO NOT SCALE DWG.			
The information and design disclosed herein was originated by and is the property of STACO ENERGY PRODUCTS CO., which reserves all patent, proprietary, design, manufacturing, reproduction, use and sale rights thereto, and to any article disclosed therein except to the extent rights are expressly granted to others. The foregoing does not apply to vendor proprietary parts.						CHECKER B. FOX		DATE 1/27/25		WEIGHT APPROX.		CAGE CODE 83008		DWG. SIZE		DWG. NO.			
						ENGINEER B FOX		DATE 1/27/25		SCALE 1=8		SHEET 1 OF 1		D		096-6294			