




DWG. SIZE D	DWG. NO. 090-3158		
REVISIONS			
SYM.	E.C.O.	DATE	APVD.
B	30180	5/14/25	
ADD SEISMIC HOLES			

SUMMARY OF EQUIPMENT

THE E3 EXTENDED RUN TIME BATTERY CABINET IS USED IN CONJUNCTION WITH THE E3 UPS TO PREVENT THE LOSS OF ELECTRONIC INFORMATION AND MINIMIZE EQUIPMENT DOWN TIME. DURING BROWNOUTS, BLACKOUTS, AND OTHER POWER INTERRUPTIONS. THE BATTERIES PROVIDE EMERGENCY POWER TO SAFEGUARD OPERATION.

THE E3 EXTENDED RUN TIME BATTERY CABINET IS SUPPLIED WITH INTERNAL FUSING. THE CIRCUIT BREAKER, WHEN CONNECTED TO THE UPS, WILL TRIP IF THE EMERGENCY POWER OFF (EPO) BUTTON IS PRESSED.

ENVIRONMENTAL

OPERATING TEMPERATURE: 0°C TO 40°C
ALTITUDE: 0-3300 FEET [1000 METERS] (WITHOUT DERATING)
RELATIVE HUMIDITY: 0-90%, NON-CONDENSING

POWER TERMINAL CONNECTIONS:

BOX COMPRESSION TERMINALS
2/0 - #6 AWG WIRES

UL LISTED TO UL 1778, FILE NO.: E191175

MODEL		CIRCUIT BREAKER RATING (AMPS)		FUSE RATING (AMPS)	
E3-BAT-390-60-1-CSST		60		60	
UNLESS OTHERWISE SPECIFIED, TOLERANCE IS ± DECIMALS .XX .010 .XXX .005	HOLES .005	ANGLES 1°	DRAFT 1-1/2°	UNITS IN [mm]	STACO ENERGY PRODUCTS CO. A Components Corporation of America Company 2425 Technical Drive Miamisburg, Ohio 45342 USA
MATERIAL :				ALL DIMENSIONS APPLY AFTER PLATING	
The information and design disclosed herein was originated by and is the property of STACO ENERGY PRODUCTS CO., which reserves all patent, proprietary, design, manufacturing, reproduction, use and sale rights thereto, and to any article disclosed therein except to the extent rights are expressly granted to others. The foregoing does not apply to vendor proprietary parts.				DRAWN BY R. GILBERT	
				CHECKER	
				ENGINEER	
TITLE: SPEC. CONTROL DRAWING E3-BAT-390-60-X EXTENDED RUN-TIME BATTERY CABINET		DATE 5/14/25	FIRST USED ON E3	DO NOT SCALE DWG.	STACO ENERGY PRODUCTS CO. A Components Corporation of America Company 2425 Technical Drive Miamisburg, Ohio 45342 USA
		DATE	WEIGHT APPROX.	CAGE CODE 83008	
		DATE	SCALE 1:8	SHEET 2 OF 2	
		DATE	SCALE 1:8	SHEET 2 OF 2	

DWG. SIZE D	DWG. NO. 090-3158
-----------------------	----------------------

